

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

abcdefghijklm. XLS Limit Switch.

XP / I / 1 / A*BCD / T5 Ta = 80°C; DIP / II / 1 / EFG / T5 Ta = 80°C; Type 4X

a = Actuator size 00, 02, 03, 05, 06, 07, 08, 09, 10, 12, 14, 15, 16, 18, 20, 30, or 40.

b = Thread and mount type 0, 1, 2, 3, 4, 5, 6, 7, or 9.

c = Drive type -, 0, S, F, D, K, N, M, or R.

d = Actuator / solenoid valve type 0, 1, 2, 3, 4, 5, 6, 7, 8, or 9.

e = Spring return type 0, 1, 2, 3, 4, 5, 6, 7, 8, or 9.

f = Switch options 1, 4, 5, 6, 7, 9, A, B, C, D, E, F, G, H, K, or M.

g = Approval type F or P (*P includes Group A for the US)

h = Options 0, B, C, D, E, F, G, or P.

i = Entries A, B, C, or D.

j = LED Options 0, 1, 2, 3, or 4.

k = External mounting options 0, 1, 2, 3, 4, or 5.

l = Terminals 0, 4, 5, or 6.

m = Indicator 0, A, or R.

Equipment Ratings:

Explosionproof for Class I, Division 1, Groups A, B, C, & D; T5 Ta = +80°C; dust-ignitionproof for Class II, Division 1, Groups E, F, & G, T5 Ta = +80°C; indoor and outdoor (NEMA Type 4X) hazardous (classified) locations

FM Approved for:

Kinetrol, Ltd.
Trading Estate
Farnham, Surrey
GU9 9NU United Kingdom

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3615	2006
Class 3810	2005
ANSI/NEMA 250	2003

Original Project ID: 3027769

Approval Granted: *July 19, 2007*

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC


Robert L. Martell, Jr.
Assistant Vice President

July 19, 2007
Date